MAT JOURNALS
Journal of Controller and Converters
Volume 2 Issue 1

Single Phase New Upfc Concept of Transmitting Power

"[1]M.tech scholar" [1*]Ritu Gautam, [2]Dr. Pramila Kaniyar
Asst. Prof., Department of Material Science and Engineering,Dayanandasagar college of Engineering.
[1]Department of Electrical Engineering.
Email- pramilakaniyar@gmail.com

Abstract

The main focus of this paper is flexible AC Transmission system (facts) tool called the Unified energy flow Controller (UPFC). We understand that Unified energy glide Controller (UPFC) has precise functionality to manipulate concurrently real and reactive power flows on a transmission line as well as to alter voltage on the bus wherein it is related, this class of flexible AC Transmission system (facts) tool creates a first-rate pleasant effect on strength system stability. these features end up even more significant knowing that the UPFC can allow loading of the transmission traces close to their thermal limits, forcing the power to go with the flow through the desired paths. this can deliver the strength device operators a great deal wished flexibility as a way to fulfill the needs that the deregulated power device will impose. The most value-effective manner to estimate the effect the Unified power waft Controller (UPFC) has on a selected electricity gadget operation is to simulate that devic e together with the UPFC with the aid of the usage of one of the current simulations applications. mainly, the objective of this paper is to expand a single segment Unified energy go with the flow Controller (UPFC) version that can be integrated in to existing MATLAB. As it is recognized that UPFC has parts one is in shunt and different is in series with the transmission line, however in conventional UPFC those two parts are connected and designed to put in a single corner of strength grid. An attempt, in this paper had made to separate or enlarge the collection part and shunt a part of Unified strength go with the flow Controller (UPFC). This offers the opportunity to established collection and shunt part of UPFC at exceptional required locations. sooner or later the responses of two changed DC link UPFC is compared.

Keywords*: facts (flexible AC Transmission gadget), UPFC (Unified energy drift Controller),VSC (Voltage source Converter), STATCOM (Static Synchronous Compensator), SSSC (Static Synchronous series Compensator).*

INTRODUCTION

Unified energy go together with the float Controller (UPFC) is the most flexible converters some of the bendy AC Transmission device (facts) gadgets [1-5].It contains of two voltage supply converters (VSC), one is hooked up with parallel with transmission line to insert a reactive power within the transmission line and other is connected with collection with the transmission line to insert lively energy inside the transmission line, by means of this manner this converter will compensate the reactive energy and lively strength all collectively or independently [10]. Because the change of energetic and reactive power is taking vicinity in among the shunt and series part, the place of collection and shunt component is of most important. The power system balance, performance and disturbance problems in strength machine are undefined inside the grid. to enhance the energy system stability efficiency, the shunt part of Unified power drift Controller UPFC need to be placed inside the vicinity from where

it can lower the impact of voltage adjustments and the series element need to be located inside the vicinity in which its parameter adjustments effect the variant of lively and reactive strength the most [2,3,9]. As to fulfill the above require men right here, the real function of unmarried segment UPFC with changed DC hyperlink among the series and Shunt parts of traditional UPFC is supplied inside the paper. For simulation in MATLAB 7.zero model is used to obtain the real wave shape of the injected voltage to the shunt a part of Unified electricity float Controller (UPFC), output energetic and reactive strength wave form and the road cutting-edge wave form. The DC link of traditional UPFC has been changed with first totally removed this DC hyperlink whose responses are determined and then DC hyperlink has been changed with lengthened the DC hyperlink as in subject and one more transmission line want to be lay, and its responses are also located. sooner or later the mixed responses are as compared for simplicity here within the paper.

various observations are made most effective on a unmarried segment Unified electricity waft Controller (UPFC) the main problem we're going through right here in transmitting energy with removed DC link is the present of

harmonics which required harmonics filters at each the give up. the principle hassle became in electricity alternate among series and shunt part of UPFC. here the hassle is solved with the aid of surely lengthening the DC connector among the collection and shunt element and other element is grounded to conquer the hassle of harmonics. Ignoring the value worried in laying one greater line, this method can be used to enhance the device stability situation the usage of UPFC with lengthening DC link, and in which we are able to deploy the UPFC in our required area. The systematic diagram is:-



Fig 1.1 *Unified strength flow Converters*

NEW IDEA OF STRENGTH TRANSMITION

to improve the energy device stability efficiency, the shunt part of Unified power glide Controller(UPFC) have to be positioned in the place from wherein it may lower the impact of voltage modifications and the series element have to be placed in the place where its parameter modifications the effect of the variation of active and reactive energy the most. For the above motives, commonly in a power gadget network, shunt and series gadgets ought to be positioned at one of a kind places. however, because of the power trade, the shunt and series parts of the UPFC should beat the identical vicinity. The paper presents a brand new approach of power transmission thru existing strength line but atone of a kind

frequency, which offers freedom to separate the collection and shunt part of the Unified energy glide Controller (UPFC).The single section energy device is with UPFC is built in MATLAB simulation and the evaluation were made.

CHARACTERISTICS OF UPFC

The fundamental additives of the UPFC are voltage source inverters (VSI's) sharing a commonplace dc storage capacitor, and connected to the machine through coupling transformers. One VSI is hooked up in shunt to the transmission device through a shunt transformer, at the same time as the alternative one is attached in series thru a series transformer. A basic UPFC functional scheme is shown in Fig.1.1. The series part is controlled to inject a symmetrical 3 section voltage system, Vse, of controllable significance and section attitude in series with the line to manipulate active and reactive strength flows on the transmission line. So, this shunt and series parts will change lively (P) and reactive electricity (Q) with the road. The reactive electricity is electronically furnished by means of the series inverter, and the energetic electricity is transmitted to the dc terminals. The shunt inverter is operated in such a way as to demand this dc terminal strength (positive or poor) from the road preserving the voltage throughout the garage capacitor Vdc consistent [6-10]. So, the net real electricity absorbed from the road via the UPFC is same most effective to the losses of the two inverters and their transformers. The final potential of the shunt inverter can be used to trade reactive electricity with the line to be able to provide a voltage regulation at the relationship point. the two VSI's can work independently of each different through separating the dc facet. So in that case, the shunt inverter is operating as a STATCOM [9] that generates or absorbs reactive electricity to alter the voltage value at the relationship point. As a substitute, the series inverter is running as SSSC that generates or absorbs reactive strength to adjust the contemporary flow, and subsequently the electricity flows at the transmission line [4, 5, 8].



Fig 1.2 *Schematic Diagram of separated UPFC*

In above figure indicates that the unmarried line diagram of prolonged UPFC with line impedance L , here the a DC line is prolonged to the distribution side with most effective a unmarried line. The 2 condensers are used to balanced instantaneous difference inside the essential power. The shunt component and series part of UPFC can be separated to preferred vicinity. V_i and V_j represents the 2 terminal voltages on bus bar, this UPFC is set up in between the phase of bus bar (i& j).

SIMULATION RESULT

As shown in above determine, the energetic energy and reactive electricity of DC link extended is bit lesser then that of DC hyperlink separated. This under figure shows the output graph of extended (long) DC link UPFC, the active and reactive strength. whilst compared with the ordinary UPFC (shown in beneath parent it's far discovered that this extended UPFC's power switch potential decreased a bit. the line cutting-edge of lengthy UPFC has a chunk distinctive wave form with in comparison to everyday UPFC line contemporary; this is simplest due to presence of harmonics in it.



Fig 1.3 *The output graphs showing Reactive and energetic power of prolonged UPFC*



Fig 1.4*Active and Reactive electricity graph for regular UPFC*



Fig 1.5 *Graphs showing Line current and injected voltage*



Fig 1.6 *output lively power and reactive energy*

Fig 1.6 shows the output active electricity and reactive electricity at sending quit receiving quit and line present day and injecting voltage, there may be some distortion in the line present day because of a few presence of harmonics. The entire system is offered in PU machine.



Fig 1.7

Fig 1.7 The proposed model is run in MATLAB, and compared with the regular UPFC energetic power (P(ordinary)).The respective graphs are shown in fig 1.4 and fig 1.five it is visible that there is a some drops in the energetic strength due to modified DC link, however over all this new UPFC works precisely because the conventional UPFC. Though the power transfer functionality is bit less then the conventional UPFC however there may be better flexibility of set up of UPFC, on the grounds that both the parts may be set up at special vicinity.

CONCLUSIONS

The paper gives a unmarried section new UPFC idea of transmitting power with

modified DC link between collection and shunt part of UPFC, which gives greater flexibility of UPFC installation. The energetic strength trade among shunt and series is transmitted through a unmarried DC transmission line. The UPFC can be set up at distinct region with prolonged DC link that allows you to reduces the effect of harmonics problems encounter in UPFC with removed DC link. but it reduces the electricity transmission functionality as proven in end result and extra lossless within the transmission line and transformers. but each the modified UPFC have the complete feature as conventional UPFC. The Separated series part of this UPFC will reduce the cost considerably and feature a variety of greater benefits, such as better reliability, handy for set up and protection.

REFERENCES

1. L. Gyugyi, "Unified energy waft manipulate concept for bendy AC Transmission structures," in Proc. 5th global conference on AC and DC energy Transmission Conf., IEE, issue 345, pp 19-26, London, uk, 1991.
2. I. Papic, P. Zunko, D. Povh, M. Weinhold, "basic control of Unified power float Controller," IEEE Transactions on strength structures,v. 12, n.4, p.1734-39, Nov. 1997.
3. Z. Huang, et al., "application of Unified energy drift Controller in Interconnected power systems – Modeling, Interface, manipulate approach and take a look at Case," IEEE Transactions on energy structures, v.15, n.2, p.817-24, can also, 2000.
4. [E. Uzunovic, C. Cañizares, J. Reeve, "essential Frequency version of Unified power waft Controller," in Proc. North American strength Symposium NAPS, Cleveland, Ohio, Oct. 1998, pp. 294-99.
5. ok. ok. Sen, E. J. Stacey, "UPFC-Unified energy float Controller: concept, Modeling and packages," IEEE Transactions on power delivery, Vol. thirteen, No. 4, Oct. 1998. pp.1953-60.
6. R. L. Vasquez-Arnez, L.C. Zanetta J., "Unified power drift Controller (UPFC): its Versatility in dealing with power drift and interplay with the network," in Proc. IEEE/PES Transm. &Distrib. convention, Asia Pacific, Vol. 2, Oct. 6-10 Yokohama, Japan, 2002. pp.1338-forty three.
7. okay. Duangkamol, Y. Mitani, okay. Tsuji, M. Hojo, "Fault modern-day limiting and energy gadget Stabilization by using Static Synchronous series Compensator," in Proc. global conference on energy device technology (PowerCon2000), Australia, Dec. 2000. p.1581-86.
8. M. Takeshita, H. Sugihara, "effect of Fault modern-day restricting of UPFC for strength go with the flow control in Loop Transmission," in Proc.IEEE/PES Transm. &Distrib. convention and Exhibition 2002, Asia Pacific, Oct. 6-10, 2002, Vol. 2, pp. 2032 –36, Yokohama, Japan,2002.
9. Vasquez Arnez, R. L; Zanetta, L.C.; effective challenge of Line Fault Currents by way of series-related VSI-based information devices. In: X Symposium of professionals in electric powered Operational and growth making plans, Florianópolis, Brasil, X SEPOPE, 2006
10. A. Karami-Mollaee and M. R. Karami-Mollaee, "a new technique for instant pole placement with recurrent neural networksand its software on top of things of nonlinear time-varying systems," structures & control Letters, vol. fifty five, pp. 385-395, 2006.
11. Y. Zhang, okay. Chen, and W. Ma, "MATLAB simulation and contrast of Zhang neural community and gradient neural network of on line answer of linear time-varying equations," DCDIS Proc. global conference on existence

system Modeling and Simulation,Shanghai, 2007, pp. 450-454.
12. Y. Zhang and S. S. Ge, “layout and analysis of a standard recurrent neural community model for time-various matrix inversion,” IEEE Transactions on Neural Networks, vol. sixteen, no. 6, pp. 1477-1490, 2005.
13. The MathWorks Inc., using Simulink, version 6.6, Natick, MA, 2007;
14. Weimu Ma, Yunong Zhang, Member, IEEE, and Jiahai Wang, “MATLAB Simulink Modeling and Simulation of Zhang NeuralNetworks for on line Time-varying Sylvester Equation solving”.
15. A. Garcia-Cerrada, P. Garcia-Gonzalez, 'control device for a UPFC in a Transmission Line', EPE ninety nine, Lausanne, Switzerland.
16. I. Papic, P. Zunko, D. Povh, 'basic manipulate of Unified energy waft Controller', IEEE Transactions on strength systems, Vol. 12, No. four,November 1997.
17. EdvinaUzunovic, Claudio A. Canizares, John Reeve, 'EMTP studies of UPFC strength Oscillation Damping', proceedings of the NorthAmerican electricity Symposium (NAPS), San Luis Obispo, CA, October 1999, pp. 405-410.
18. S. Dupuis, M. Crappe, J. Trécat, 'examine of best area and manipulate of UPFCs in a widespread electricity gadget by way of Simulation withEUROSTAG', EPE 99, Lausanne, Switzerland.
19. AlexandrZ.Gamm; Irina I.Golub: determination of locations for information and strength garage via the singular analysis, energy systemtechnology, 1998.
20. Deepak Divan: A dispensed static collection compensator system for figuring out lively power go with the flow control on existing strength traces, powerstructures conference and Exposition, 2004.
21. Pudur,Rajen,” Unified power Controller with modified DC hyperlink”, M.Tech Thesis, NERIST (Nirguli) Itanagar(ArunachalPradesh),India-2011